

CORRENDUM No. 1 of Tender No. CUSB/S&P/RE/Tender/22/2016-17

Sl. No.	Queries of Bidders/ Observation	Relevant Clause	Clarification by CUSB
1	Only single longitudinal joint is allowed in hard wood of Deck Top width of which should not be less than 200 mm. Problem: Best Shoreham Wood with sap wood not more than 50% is not available in widths above 7" such quality of wood is rare Indian of the required quantities it is almost impossible to arrange wood with such standards. Request: We request you to allow as per below Option 1: To allow 2 joints without limiting the minimum width of any of the plank. Option 2: To allow 80% red wood on the top/visible surface and 50% red wood on the bottom/invisible surface wider around 7" to 10" can be arranged if this is allowed and work can be done with single joint.	Technical Specification To be read in conjunction with Bill of Quantity, Drawings and Scope of tender. Classroom Deck With Bench Specifications (2)	Classroom Specifications (2) to be read as (2) Table TOP/SEAT/BACK/STORAGE section. The seat, back, table top & storage shelf shall be made of 20mm thick solid flat sheesham. Two longitudinal joints are allowed in hard wood of top of Desk, Bench. Please refer drawings for further details.
2	Technical Specification point "1" wherein it has been mentioned that "Only single longitudinal joint is allowed in hard wood of deck top width of which should not be less than 200 mm.	Technical Specification To be read in conjunction with Bill of Quantity, Drawings and Scope of tender. Classroom Deck With Bench Specifications (2)	Same as above
3	Use shoreham wood with 50% sap wood. Also please permit to use multiple wood joints on deck top and bench seat.	Technical Specification To be read in conjunction with Bill of Quantity, Drawings and Scope of tender. Classroom Deck With Bench Specifications (2)	Same as above