

Order No. - 107 No. - CUB&PQ/LAW/19804/198/2025-25
"Establishing the Most Court and Legal Aid Clinic" in JAW Dept., CUB&PQ

Reply of queries of pre-bid meeting

S. No.	Reference	Question	Bidder Request	Reply
1	Page no. - 09 Item No. - 02	Arrangement we have to do on Wood & Plywood work Scaffolding, Painting / Polishing	Apply Wood primer only on Scaffolding Guard Post.	New Wood bid required to be provided with one coat of Black Japen Paint
2	Page no. - 09,10 Item No. - 03, 05, 04, 05 & 07	Is market 12mm Brick Weathered commercial plywood is not available.	we may provide 12mm brick commercial plywood B&G grade	12mm brick commercial commercial plywood to be provided as per the tender specification.
3	Page no. - 09 Item No. - 06	Plaster (see: 8) items a Plaster we have to provide, but due to long span it required support at bottom to bear heavy weight.	we may provide the steel of size 112x12mm-2 the supporting bottom with one side steel profile.	we may provide one intermediate wood support to be provided under the 18 mm thick plaster plywood.
4	Page no. - 09,11 Item No. - 08 & 09	Is 12mm Commercial Plywood not available in market. Is B&G used for B&G Plywood	we may provide 12mm brick commercial Plywood as its cover part.	12 mm thick commercial plywood to be used.
5	Page no. - 11 Item No. - 10	Top bar - 22mmx20mm Made of Hot Weathered wood	wood will not be available of 22mm width in our plant, then we will get minimum 2 to 3 joints, it will get hot crack over joint after some time. we may provide 18mm brick commercial plywood B&G grade	Weathered wood top with upto 02 joints in width can be provided. (only one joint will not be acceptable).

Additional details

1.	Red Weathered Wood - The wood shall be high quality Red Greenish wood containing sapwood as per relevant IS code. It should be kiln dried and chemically treated for termite protection. The wood moisture content level to be as per relevant IS Code. All joints must be bonded using water resistant B&G grade adhesive. All wood surfaces shall be protected with oil Coats of Solar resistance finish in apartment small for weather finish.
2.	Weathered Commercial Plywood (To be used as) - Plywood with one side of weather resistant and one side commercial weather.
3.	Paints: All wood (plywood/weathered surfaces (wood/brick/stone) to be provided with 02 coats of moisture paint in approved shade.


Assistant Engineer