

Tender No - NIT No. - CUSB/PSD/LAW/TENDER/03/2020-21
"Establishing the Moot Court and Legal Aid Clinic" in LAW Dept., CUSB

Reply of queries of pre-bid meeting

S. No.	Reference	Question	Bidder Request	Reply
1	Page no. - 09 Item No. - 01	What treatment we have to do on Wood & 18mm thick MR Ply wood. Painting / Polishing	Apply Wood primer only. OR Synthetic Enamel Paint.	Fine Wood MR Plywood to be painted with one coat of Black Japan Paint
2	Page no. - 09,10 Item No. - 02, 03, 04, 06 & 07	In market 12mm thick Sheesham veneered plywood is not available.	We may provide 12mm thick veneered plywood MR grade.	12/18 mm thick sheesham Veneered plywood to be provided as per the tender specifications.
3	Page no. - 10 Item No. - 06	Platform Size - 820mm x 750mm we have to provide, but due to long span it required support at bottom to bear heavy weight.	We may provide Pine Wood of size 132x35mm 2 Pes horizontal at bottom with one cote wood primer.	02 Nos 132x28 mm Sheesham wood support to be provided under the 18 mm thick platform plywood.
4	Page no. - 10,11 Item No. - 08 & 09	IS : 303 Commercial Plywood not available in market. IS:303 stand for MR Plywood.	We may provide 12mm thick commercial Plywood as its inner part.	12 mm thick commercial plywood to be used.
5	Page no. - 11 Item No. - 10	Top Size - 1200x600x28mm Made of Red Sheesham wood	Wood will not be available of 600mm width in one pec., there will be minimum 2 to 3 joints, it will get hair crack over joint after some time. We may provide 18mm thick veneered plywood MR grade.	Sheesham wood top with upto 05 joints in width can be provided. Cracks over joints will not be acceptable.

Addition at details

1.	Red Sheesham Wood :- The wood shall be high quality Red Sheesham wood containing sapwood as per relevant I.S. code. It should be kiln dried and chemically treated for termite protection. The wood moisture content limit to be as per relevant I.S. Code. All joinery must be bonded using water resistant D3 grade adhesive. All wood surfaces shall be protected with 03 Coats of Satin Malmine Polish in approved shed for smooth finish.
2.	Sheesham Veneered Plywood:- (To be read as) :- Plywood with one side sheesham veneer and one side commercial veneer.
3.	Polish:- All wood/plywood/veneered Surfaces (front/back/inner) to polished with 03 coats of malmine polish in approved shade.


Assistant Registrar