



CENTRAL UNIVERSITY OF SOUTH BIHAR

SH-7, Gaya- Patanchpur Road, Village- Karkens, Post- Patanchpur,
P.S- Takail, District- Gaya (Bihar) PIN- 824 238

Date: 12/02/2020

Corrigendum Notice

Tender Notice No.: CUSB/PSO-ADMIN/T/19/2019-20, Dated 29-01-2020

(Construction of 30.5 Mtr. (100 feet) high National Flag Mast & 10 Mtr. high Lighting Mast with Luminaries)

Refer to above mentioned tender notice and Pre-bid meeting held on 05/02/2020, the following corrigendum is published for queries received during Pre-bid meeting/ e-mails from prospective bidders.

Sl. No.	Page No. as per tender document	Tender Reference Clause No.	Query received from prospective vendor	Clarification by CUSB, Gaya
1.	10	List of approved material	For Item No. 22, request for acceptance of any CPW approved or tender approved make.	May be considered CPW approved outdoor Electrical Panel preferably listed in tender list
2.	06	06	Request to put in minimum make products in the tender	Not considered. No changes in tender documents in this regard.
3.	02	Luminaries: The flood light luminaries (LUP 215) power control, die cast aluminum housing with frame, heat resistant clear toughened glass fixed to the frame with silicon-gasket with electrochromically toughened, polished and anodized aluminum reflector with cast aluminum control gear box copper backed 400 W Mtr T. Lamp (IP-65). The warranty of Lamp should be minimum 3 years. This flood light shall be installed on suitable pole on plinth with supply & laying of 30x2.5 square copper cable for the individual wiring of the luminaires.	Conventional fitting are not energy efficient and are now being phased out. Also lamps being a diffusion time are not covered under warranty. We suggest to use LED floodlight fittings of 200 Wattsage against requirement.	200 watt LED IP-65 instead of 400 watt conventional lights.

SD/-
Registrar