



# CENTRAL UNIVERSITY OF SOUTH BIHAR

SH-7, Gaya- Panchanpur Road, Village- Karhara, Post- Fatehpur,  
P.S- Tekari, District- Gaya (Bihar) PIN- 824 236

Date: 12/02/2020

## Corrigendum Notice

**Tender Notice No.: CUSB/PSD/ADMIN/T/19/2019-20, Dated 29/01/2020**  
**(Construction of 30.5 Mtr. (100 feet) High National Flag Mast & 16 Mtr. High Lighting Mast with Luminaries)**

Refer to above mentioned tender notice and Pre-bid meeting held on 05/02/2020, the following corrigendum is published for queries received during Pre-bid meeting/ e-mails from prospective bidders.

Sl. No.	Page No. as per tender document	Tender Reference/ Clause No.	Query received from prospective vendor	Clarification by CUSB, Gaya
1.	16	List of approved material	For item No. 22, request for acceptance of any CPRI approved or vendor approved make.	May be considered CPRI approved outdoor Electrical Panel preferably listed in tender list.
2.	-Do-	-Do-	Request to put in Valmount make products in the tender.	Not considered. No changes in tender documents in this regard.
2.	22	<b>Luminaries:</b> The flood light luminaries (BJEF 215) power coated die cast aluminum housing with frame, heat resistant clear toughened glass fixed to the frame with silicon gasket with electrochemically brightened, polished and anodized aluminum reflector with cast aluminum control gear box copper ballast 400 W MH T Lamp (IP-66). The warranty of Lamp should be minimum 3 years.  This flood light shall be installed on suitable pole on plinth with supply & laying of 3Cx2.5 sqmm copper cable for the individual wiring of the luminaire.	Conventional fitting are not energy efficient and are now being phased out. Also lamps being a diffusible itme are not covered under warranty. We suggest to use LED floodlight fittings of 350 Wattage against the requirement.	350 watt LED IP-66 instead of 400 watt conventional lights.

Sd/-  
Registrar